




OIL FILTRATION SYSTEMS

CJC™ Application Study

Hydro Power Station - Governor System



INDUSTRY

Application Study written by
Hjalmar Sørgård,
Øvre-Johnsen AS (N)

in cooperation with

Steffen Buhrkal,
C.C. Jensen A/S (DK)

CUSTOMER

Statkraft, Region Nord-Norge.
Contact person: Torstein Elvegård



THE SYSTEM

Governor oil system for Hydro Turbine. Oil volume: 5,200 L of hydraulic oil.



THE PROBLEM

The governor oil system was suffering from irregular and deviant operation caused by resin (oxidation) formation in the valves. The resin formation was identified as a sticky brown layer on all surfaces in the system. Due to resin formation valve malfunctions were becoming frequent, causing unplanned shut-downs.

The consequence of the contamination was that the valves had to be removed and cleaned up to 4 times a year at a cost of EUR 800 each time. The cost of a new valve is EUR 3,000.

THE SOLUTION

In order to arrest the problems and ensure continuous operation a CJC™ Off-line Fine Filter type HDU 27/54 MZ was installed. Two cellulose based filter inserts type B 27/27 (3µ absolute) were used. Cellulose is a highly polar material which ensures efficient adsorption of the resin from the oil system.



CJC™ Fine Filter HDU 27/54 MZ

CONCLUSION

Despite the fact that the oil initially had a cleanliness which should indicate smooth and problem free operation the resin formation was causing irregular operation of the system.

The conclusion is that conventional surface filters are indispensable as in-line police filters, but they are not able to remove resin formation. The cellulose filter inserts in the CJC™ Off-line Fine Filter type HDU 27/54 MZ, however, adsorb the resin.

After just one month of filtration the turbine operation has become stable and without interruptions.

THE RESULTS

| Date | Water content (ppm) | NAS |
|----------|---------------------|-----|
| 07.11.00 | 245 | 5 |
| 15.11.00 | 25 | 3 |
| 30.11.00 | 55 | 3 |
| 15.12.00 | 30 | 1 |



C.C. JENSEN

C.C.Jensen A/S * Løvholmen 13 * DK-5700 Svendborg * Denmark
Phone: +45 63 21 20 14 * Fax: +45 62 22 46 15
E-mail: filter@cjc.dk * Web: www.cjc.dk